

## ENTERPRISEWIDE SPCC MONITORED TRAINING

A self-paced,  
Web-based module

Equipment Operation & Maintenance  
Procedures to Prevent Discharge

- Oil/Water Separators (Valves)
- Tank High Level Alarms
- Nozzles dispensers
- Refueler High Level Shutoffs
- Portable Tanks

Discharge Protocols: what to do for a spill

FRA guidelines

Stop spill or call for help

Clean up

Notify Environmental Affairs: they will report

### Pollution Laws, Rules & Regulations

- Clean Water Act and Amendments
- Title 40 CFR Part 112 Rules
- State or Local Regulations

#### Clean Water Act and Amendments

- Drives Stormwater and SPCC Plans
- Requires Self Reporting of Oil Spills to Navigable Waters

Title 40 CFR Part 112 Rules

- Must have Plan for more than 1,320 gallons in aboveground storage
- Secondary Containment or equivalent for Oil Storage and Use

- Add specific local requirements here
- Add links to site specific SPCC Plans
- Add links for site specific General Facility Operations

#### SPCC Plan Contents

- Must address oil containers  $\geq$  55 gallons
- Reviewed by Professional Engineer
- Management commitment of resources
- Oil includes Skydrol, olive oil, etc.
- Documents:
  1. compliance with rules & regulations
  2. discharge & drainage controls
  3. spill prevention measures

- Portable Tanks, containers, bowzers,

- Known discharges, spills and near misses from around the enterprise

- Failures and Malfunctions of Components
- Include maintenance procedures and problems

